C-8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NZ/2026/856 Dated: 09/09/2026

To

The Principal,
Holy Heart School,
C-11, Vijay Nagar, Delhi.

Sub:- Regarding issuance of Fire Safety Certificate (FSC) in r/o **Holy Heart School, C-11, Vijay Nagar, Delhi.**

Sir,

This has reference to email dated 13.07.2026 on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned of this department on 25.08.2026 in the presence of Manager and it was observed that building is comprised of ground + 03 upper floors but school running at 1st and 2nd floor only. During the inspection, following shortcomings were observed:-

1. Single staircase of 0.87 to 1.07 m has been provided against the required width of 1.5 m.
2. The width of door is 0.77 to 0.85 m against the required width of 1.0 m.
3. Fire extinguishers provided but non functional.
4. First aid hose reel hose not provided.
5. An overhead water storage tank capacity of 2,000 ltrs. provided against the requirement of 10,000 ltrs. exclusively for firefighting.
6. Exit signates are not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,

9/9/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:-.
The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.