GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2025/ 872 Dated: 14/09/2026

To

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Hotel Airport Inn located at A-7, Road No. 1, Mahipalpur Extension, New Delhi 37.

Sir,

With reference to the MCD/MHA online application no. 2026080710352 on the subject cited above, it is informed that the said Guest House was visited by officer concerned of this department on 31.08.2026 in the presence of Mr. Amit Kumar (Manager) and following shortcomings were observed:

1. Fire Check Doors has not been provided.
2. All water based Systems like Fire Pumps, Hose Reels, Sprinklers are non- functional.
3. Smoke management system (Exhaust fans) found removed.
4. CO detector found removed.
5. MOEFA has not been provided.
6. The plan uploaded is not matching the site at Ground and 2nd floors.

In view of above shortcomings, the application of issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

10/9/26

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

10/9/26

Copy to:-

1. The Licensee, M/s Hotel Airport Inn located at A-7, Road No. 1, Mahipalpur Extension, New Delhi 37.