C/9

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2025/GH/ 473 Dated: 08 /12/2025

To

The Commissioner,
Municipal Corporation of Delhi.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Hotel Ashok International at 3382, Christian Colony, D.B.G Road, Karol Bagh, New Delhi-110005,

Sir,

Please refer to online MCD Portal ID No- 2025102914455 dated: 30/10/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 21/11/2025 to check the existing fire safety measures. During inspection it has been observed that the building was comprised of Basement, Ground, Mezzanine & 04 upper floors, Basement (other ownership), Ground floor (Reception + 03 guest rooms), mezzanine floor (sealed), 1st floor to 3rd floor (06 guest rooms at each floor), total 21 guest rooms only and 4th floor was sealed by the guest house management. At the time of inspection Sh. Mahesh Kumar was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Smoke ventilation system is provided but not functional.
2. Smoke detector system is provided but not functional.
3. Terrace level fire pumps not in auto mode.
4. Terrace level fire water tank capacity of 5000 Ltr is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.
5. Standby power supply found removed at site.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. Applicant may be requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of this guest house is at your own risk & responsibility.

Yours faithfully

5/12/25

A.K. Malik
Dy. Chief Fire Officer
Delhi Fire Service