C-14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DLEHI - 110 001

No. F.6/DFS/MS/WZ/GH/2026/217

Dated: 12/03/2026

To,

Mr. Narinder Singh,
House Building No.8, 2nd floor,
Front Side, G Block, Uttam Nagar,
Delhi-110059.

Sub: Issue of FSC in r/o M/s Hotel Da Marion located at WZ-3535 A/1, Raja Park, Shakur Basti, Delhi-110034.

This is reference to online application no. 2026020801393 dated 08.02.2026, received in this department on the subject cited above. In this connection it is to inform you that the building premises has been visited by the officers concerned of this department on 18.02.2026 presence of Mr. Narinder Singh (Occupier) and observed that the shortcoming already issued by this department letter of even No. 2890 dated 04.07.2018 are not yet rectified and further additional shortcomings observed are as follows:

1. Shortcoming already conveyed are not yet rectified.
2. The width of corridor is 1.35 mtr against the required width of 1.80 mtr.
3. Smoke management system is not provided in upper floor.
4. First Aid hose reel is provided but not functional.
5. MOEFA is found removed.
6. Public Address System is found removed.
7. Internal hydrants not provided.
8. 10,000 ltrs Over Head water captive tank is found removed.
9. Terrace Fire pump with capacity of 900 LPM found removed.
10. Exit signage found removed.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 you may advise the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

Encl: As above

12/03/26
(S. K. Dua)
Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Copy To:-

1. MCD Portal Id- 2026020801393 dated 08.02.2026.