GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/SZ/2025/GH/437 Dated:- 06/11/2025

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi -110002.

Sub.:- Regarding issuance of Fire Safety Certificate in r/o M/s Hotel Grand Shalimar, located at Plot No. 20, New No. 289C, Kh. No. 419, 1 & 2, Mahipalpur, Delhi-110037.

Sir,

This has reference to online application nos. 2025100713998, 2025100713996 dated 07/10/2025 & 2025101314170 dated 13/10/2025 on the subject cited above. In this connection, it is to inform you that the above said building was inspected by the officer concerned of this department on dated 28/10/2025 in the presence of Sh. Satbhan Sehrawat (Owner). During inspection observed that the above said building is comprised of basement + ground + 03 upper floors. However, the following shortcomings were observed:-

1. Exit Signages are not provided in the building.
2. Lift Signages are not provided in the building
3. The floor wise building plan and elevation plan are not uploaded on the MCD Online Portal.

In view of the above shortcomings, the application for issuance of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

06/11/25

A.K. Malik
Dy. Chief Fire Office (SZ)

06/11/25

Copy to:-

1. The Authorized Signatory, M/s Hotel Grand Shalimar, located at Plot No. 20, New No. 289C, Kh. No. 419, 1 & 2, Mahipalpur, Delhi-110037.