C-61

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2026/234 Dated: 19/03/2026

To,

The Commissioner,
Municipal Corporation of Delhi
Civic Center, New Delhi – 110002.

Subject: - Regarding Grant of Fire Safety Certificate in r/o M/s Hotel Paradise International located at A – 272, NH – 8, Mahipalpur, Delhi – 110037.

Sir,

Please refer to your MCD Portal application No. 2026021801739 dated 19/02/2026 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on 07/03/2026 in the presence of Mr. Naresh Kumar Sharma (Owner) and observed that the shortcoming is still not complied with as issued by this department vide letter no. F6/DFS/MS/GH/NDZ/271 dated 03/06/2025 (copy overleaf).

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

16/3/26

(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service
O/C @

Enclosed: As above

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

C-55

No.F6/DFS/MS/GH/NDZ/271

Dated: 03/06/2025

To,

The Manager,
M/s Hotel Paradise International,
A-272, NH-8, Mahipalpur, Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/s Hotel Paradise International, A-272, NH-8, Mahipalpur, Delhi.

Sir,

This has reference to on line ID No. 202505050107689 dated 01/05.25, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 21/05/25 in the presence of Mr. Basant and following shortcomings were observed:

1. Hose reel & pump found nonfunctional.
2. MOEFFA found nonfunctional.
3. PA system found nonfunctional.
4. 03 rooms filled in application form whereas 02 room is at the site, required to be clarify.
5. Building plan of the premises is also not uploaded on the portal.

In view of above e, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify/ clarify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

3/6/2025

(Virendra Singh)
(Chief Fire Officer)
for DIRECTOR
Delhi Fire Service

Copy to:

Addl. Commissioner of Police (Lic), Ist floor, Defence Colony Police Station, New Delhi.