GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/SZ/2026/ 652 Dated: 27/07/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Hotel The Class (Guest House) located at A-282, NH-8, Mahipalpur, New Delhi-37, building comprised of Basement + Ground + 03 upper floors: Basement – Storage, Ground floor- Reception + 03 guest rooms, 1st floor - 07 guest rooms, 2nd floor- 07 guest rooms (total 17 guest rooms), 3rd floor – Owner residence (as per affidavit dated 22.07.2026), was earlier granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/GH/2023/SZ/150 dated 12/09/2023. Now the building/premises was re-inspected by officer concerned of this department on 22/07/2026 in presence of Mr. Bobby Lohia (Owner) and building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of "Residential Sub Division-A-1" for total 17 Guest rooms (Ground floor-Reception + 03 guest rooms, 1st floor - 07 guest rooms, 2nd floor- 07 guest rooms) total 17 guest rooms only and valid for a period for Three Years form the date of issue, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on .....27/07/2026....at New Delhi by

27/7/26

(A. K. Malik)
Chief Fire officer

27/7/26

Reference: MHA/MCD application no. 2026061108699.

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, 9th floor, Civic Centre, Minto Road, New Delhi-110002:- to kindly ensure occupancy as per above detailed and check the deviation in construction, if any.
2. The Licensee, M/s Hotel The Class located at A-282, NH-8, Mahipalpur, New Delhi-37.

Conditions for the validity of Fire Safety Certificate

1. This Fire Safety Certificate is valid for Guest House Ground + 02 upper floors only.
2. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
3. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
4. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
5. The trained fire fighting staff should be available round the clock.
6. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority. Basement shall be strictly used as per BBL concerned.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
10. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

N/25

INSPECTION REPORT					
1	Name & address of the building		M/s Hotel The Class located at A-282, NH-8, Mahipalpur Extension, New Delhi-37.		
2	Building is comprised of		**Basement + Ground + 03 upper floors** **Basement** - Storage **Ground floor**- Reception + 03 Guest rooms **1st floor** - 07 Guest rooms **2nd floor** - 07 Guest rooms **3rd floor** – Owner's residence		
3	Type of occupancy		Residential, 'Group-A'' (Guest House)		
4	Type of case		Renewal		
5	Details of Previous FSC		F6/DFS/MS/GH/2023/SZ/150 dated 12/09/2023		
6	Fire Safety directive letter no.		Nil		
7	Date of inspection		22/07/2026		
8	Name of the inspecting officers		Rajesh Kumar Shukla, ADO (Jangpura)		
9	Name of the designation of officer from the building side		Mr. Bobby Lohia (Owner)		
10	Year of construction		Nil		
11	Applicant's letter no.		MHA/MCD application no. 2026061108699		
S.No	**Minimum Standards on fire Prevention and fire safety requirements U/R 33**		**Requirement as per Rule 35 (6)**	**Provided at Site**	**Remarks MR/NMR**
1	**Access to building**				
	A	Road width	Required	10.0 m	MR
	B	Gate width	NA	NA	NA
	C	Width of internal road	NA	NA	NA
2	**Number, Width, Type and Arrangement of Exits**				
	A	Number of staircases			
	a	Upper floor	1 no.	1 no.	MR (old case)
	b	Basement	1 no.	1 no.	MR (old case)
	B	Width of staircases			
	a	Upper floor	Required	1.0 m	MR (old case)
	b	Basement	Required	1.0 m	MR (old case)
	C	Protection of exits **(Required as per clause 7.31 (x) UBBL 2016 (amended)**			
	a	Fire check door	Required	Provided	MR
	b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	1 no.	1 no.	MR
	E	Width of corridor	NA	NA	NA
	F	Door size	1.0 m	1.84 m (final exits)	MR
3	**Compartmentation**				
	A	Fire check door	NA	NA	NA
	B	Sealing of electrical shafts	Required	Provided	MR
	C	Fire rating of shaft door	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	**Smoke Management System.(Required as per clause 7.31 (x) UBBL 2016 (amended)**				
	A	Basement	Required	Exhaust fans	MR
	B	Upper floor	Required	Exhaust fans	MR

5.	**Fire Extinguisher**				
	A	Total numbers	12 nos.	12 nos.	MR
	B	Types	ABC	ABC	MR
	C	ISI marking	ISI marked	Provided	MR
6	**First-Aid-Hose Reels**				
	A	Total numbers of each floor	01 no.	Provided	MR
	B	Length of hose reel hose	30 m	Provided	MR
	C	Nozzle diameter	5 mm	Provided	MR
7	**Automatic Fire Detection And Alarming System (required as per clause 7.31.viii, UBBL 2016).**				
	A	Type of detectors	CO detectors	Provided	MR
	B	Location of main panel	Required	Provided	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	Required	Provided	MR
	E	Hooters	Audible in entire building	Provided	MR
8	**MOEFA**		Required	Provided	MR
9	**Public Address System.**		NA	NA	NA
10	**Automatic Sprinkler System.**				
	A	Basement	Required	Provided	MR
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	**Internal Hydrants**				
	A	size of riser/**down-comer**	100 mm	100 mm	MR
	B	Number of hydrants per floor	1 no.	1 no.	MR
	C	Hose box	1 no.	1 no.	MR
12	**Yard Hydrants.**				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	**Pumping Arrangements.**				
	A	Ground Level			
		a Discharge of main Pump	NA	NA	NA
		b Head of Main Pump	NA	NA	NA
		c Number of main pumps	NA	NA	NA
		d Jockey pump out put	NA	NA	NA
		e Jockey pump head	NA	NA	NA
		f Standby pump out put	NA	NA	NA
		g Standby pump Head	NA	NA	NA
		h Auto Starting /Manual stopping	NA	NA	NA
		i Pump house access	NA	NA	NA
	B	Terrace Level			
		a Discharge of pump	450 LPM	450 + 180 LPM	MR
		b Head of the Pump	40 m	40 m	NA
		c Power supply	Required	Provided	MR
		d Auto starting of pump	Required	Provided	MR
14	**Captive Water Storage for Fire Fighting.**				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	D	Access to tank	NA	NA	NA
	E	Overhead tank capacity	Required	5,000 ltrs	MR
15	**Exit Signage.**		Required	Provided	MR

16	**Provision of Lifts.**				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	Required	Provided	MR
	D	Firemen's grounding switch	Required	Provided	MR
	E	Lift signage	Required	Provided	MR
17	**Standby Power Supply**		Required	Provided	MR
18	**Refuge Area.**				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA
19	**Fire Control Room**				
	A	Detector system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	PA system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plans	NA	NA	NA
20	**Special Fire Protection Systems for Protection of Special Risks, If Any:**		NA	NA	NA

LEGENDS:-Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

Note: The owner has submitted an affidavit dated 22.07.2026 stating that the 3rd floor is used as his residence.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/GH/2023/SZ/150 dated 12/09/2023 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010. Last date of disposal of this application is 27.07.2026.

22/7/26

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (Jangpura)

DO (South)

23/7/26

CFO/SZ

24/7/26

CFO to issue

24/7/26

CFO/SZ