C-141

आजादी का अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/GH/NDZ/2026/122 Dated: -11/02/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Minto Road, Civic Centre,
New Delhi -110001.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Hriday Inn Guest House, T-119, 340, General Market, Paharganj, New Delhi - 110055.

Sir,

This has reference to online application received through MCD online portal vide ID No. 2026011300428 dated 13/01/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on 21/01/2026 in presence of Mr. Zahi (Manager) and observed that the shortcomings conveyed vide this office letter No. F6/DFS/MS/GH/NDZ/200 dated 28/04/2025 (copy enclosed) has not complied as yet.

In view of above, the application for renewal of fire safety certificate cannot be considered at this stage & stands **rejected**. Further, the occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

Encl.: As above

11/2/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service
OIC BP

Copy to:

1. The Proprietor, M/s Hriday Inn Guest House, T-119 340, General Market, Paharganj, New Delhi - 110055.

C-140

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 300 Dated: 23/04/2025

To,

The Manager
M/S M/s Hriday Inn Guest House,
T-119 340, General Market, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/s Hriday Inn Guest House at T-119 340, General Market, Pahar Ganj, New Delhi.

Sir,

This has reference to Online id no. 2025032204306 dated 02.04.25, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 22/04/25 in the presence of Mr. Vishal and following shortcomings were observed: -

1. PA System non functional.
2. MOEFA found non functional.
3. Over head tank of 4000 against the requirement of 5,000.

Hence, Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police(lic), Ist floor, Defence Colony Police Station, New Delhi