C/42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/2026/WZ/Collage/ 914 Dated: 14 /10 /2026

To,

The Assistant Engineer (E),
PWD, EMDS-II, South-West,
Najafgarh, New Delhi- 110043.

Sub: - Regarding renewal of FSC in r/o Integrated Institute of Technology at Sector- 09, Dwarka, New Delhi- 110077.

Sir,

This has reference to letter No. F.No.4(42)/AE(E)/PWD S.D-II/South-West/2026-27/170 dated 11.08.2026, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the premises/building on dated 23.09.2026 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Mr. Vijay Dahiya was present and it was observed that the building comprised of Ground plus 03 upper floors, and following shortcomings were observed: -

1. Hose Reels provided but found not functional.
2. MOEFA and PA system provided but found not functional.
3. Internal hydrant provided but found not functional.
4. Fire pumps provided as per requirements but found not functional.
5. Exit Sign's found removed at few places.

In view of the above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter. The building remains unsafe from fire safety point of view and it shall be at the risk & liability of the management committee until the compliance.

Yours faithfully

10/10/26

(A.K.Malik)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Principal, Integrated Institute of Technology at Sector- 09, Dwarka, New Delhi- 77.