GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6 /DFS/MS/Redl/WZ/2026/ 403 Dated: 10 /09 /2026

To,

The Dy. Inspector General,
SHQ (L & C) I.T.B.P
Ministry of Home Affairs (G.O.I),
Najafgarh Road, Chhawla Camp New Delhi - 110071.

Subject: - Regarding grant of Fire Safety Certificate for residential and non-residential buildings at Chhawla Camp premises of ITBP.

Sir,

This has a reference to Outdoor Diary No. 4625 dated 03.08.2026, on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on 10/08/2026 in the presence of Mr. Ashok Kr Bishnoi (2nd in Command Engr) to verify the compliance of shortcomings earlier issued vide letter No. F6/DFS/MS/Redl/2026/SZ/97 dated 06/04/2026 in respect of Barrack Building (Ground plus five upper floors). During the inspection it was observed that the shortcomings have not been rectified as yet. In addition to shortcomings earlier issued, other shortcomings have also been observed. Thus, the shortcomings are as follows:

1. Fire check doors not provided some places.
2. Pressurization system was found non-functional.
3. First Aid Hose Reel provided but found nonfunctional.
4. Smoke Management System provided but found nonfunctional.
5. MOEFA provided but found nonfunctional
6. Public Address System provided but found nonfunctional.
7. Internal/Yard Hydrants provided but found nonfunctional.
8. Terrace Level Pump provided but found nonfunctional.
9. Exit & floors Signage's not provided at strategic location in the building.

Yours faithfully,

9/9/26

A. K. Mailk
Chief Fire Officer
Delhi Fire Officer

Copy to: -

1. The Executive Engineer (E) PWD EMD located at Andrews Ganj J.B. Tito Marg, opposite the Central School and near the Moolchand Flyover, New Delhi – 110049.

d/c @