G-119

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/Hospital/2026/NDZ/ 182 Dated: 14/05/2026

To,

The Assistant Engineer (Elect.)
Health Maintenance Electrical Sub-Division HE-II,
Public Works Department (GNCTD),
Jag Pravesh Chandra Hospital, Shastri Park,
Delhi-110053

Sub: - Regarding renewal of Fire Safety Certificate in r/o Jag Pravesh Chandra Hospital, Shastri Park, East Delhi-110053.

Sir,

With reference to your letter no. 19(17)/A. E(E)/PWD/HMESD HE-2/2025-26/84 dated 06/04/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 05/05/2026 in the presence of Sh. Anjan Biswas, A.E (Elect.). The hospital building comprised of basement, ground plus three upper floors. During the course of inspection following observations were made: -

1. Smoke management system in basement provided but not functional.
2. Fire damper provided but not functional.

In view of the above, the building **cannot be considered** for renewal of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above-mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully,

13/5/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Medical Superintendent, Jag Pravesh Chandra Hospital, Shastri Park, Delhi-110053
2. The Executive Engineer, Electrical Health Maint. Div. (East), B-221N, GTB Hospital Complex, Shahdara, Delhi-110095.