GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/Community Hall/2026/ 107 Dated: 16/01/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Center, Minto Road,
New Delhi–110002.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Jan Kalyan Manoranjan Samiti (Regd.) Janwasa Community Hall, OCF-1& Pocket - 1, Sector-13, Rohini- 110085.

Sir,

This has a reference to online ID. No. **202512091529** dated 15/12/2025 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 31/12/2025 in the presence of Sh. Sunil Mishra, Manager to verify the compliance of the shortcomings issued vide letter No. F.6/DFS/MS/WZ/Community Hall/2025/67 dated 17/02/2025 and observed that the shortcomings are still not complied. (Copy enclosed)

In view of the above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to comply with the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

Encl.- As above

15/01/26
(S.K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Authorized Signatory, Jan Kalyan Manoranjan Samiti (Regd.), OCF-1& Pocket - 1, Sector-13, Rohini, New Delhi–110085.
2. Nodal Officer/Delhi Fire Service.....with the request to upload on MCD portal ID No. **202512091529** dated 12/12/2025.

C/44
C/42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/Community Hall/2025/ 67

Dated: 17/02/2025

To,

Mr. Lalit Shukla (Authorized Signatory),
Jan Kalyan Manoranjan Samiti (Regd.),
OFC-1& Pocket-1, Sector-13, Rohini,
Delhi-110085.

Sub: Issue of Fire Safety Certificate (FSC) in r/o Jan Kalyan Manoranjan Samiti (REGD.) Community Hall located at OFC-1& Pocket-1, Sector-13, Rohini, Delhi-110085.

Sir,

Kindly reference to online e-mail dated 10.12.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **03.02.2025**, in presence of **Mr. Lalit Shukla** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. FCD found removed at some places.
2. Tin shed and temporary construction found affecting smoke ventilation of build and basement smoke management system found non functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(Atul Garg)
DIRECTOR
Ph; 011-23414000