**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001**

No. F.6/DFS/MS/School/2026/SZ/ 66 Dated: 05/06/2026

## FIRE SAFETY CERTIFICATE

Certified that the **J.B.M Public School** located at Nasir Pur, New Delhi–110045, earlier running at ground plus two upper floors in the building comprised of ground plus three floors, owned/occupied by J.B.M Public School, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2024/SZ/1175 dated 10/12/2024. Now, on receipt of request from school management regarding utilization of third floor of the building for school activities, the premise was re-inspected by the officer concerned of this department on 27/05/2026 in the presence of Dr. Amit Solanki (Manager) and found that the school building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the said building/premise is fit (Ground plus three upper floors) for occupancy class "Educational Group B-1" with effect from 05/06/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/06/2026 at New Delhi by

**(A.K. Malik)**
Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi–110054
2. Dr. Amit Solanki, J.B.M Public School, Nasir Pur, New Delhi–110045

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
3. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL -2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. FSC issued vide letter No. F6/DFS/MS/School/2024/SZ/1175 dated 10/12/2024 shall stand null and void after issuance of this Fire Safety Certificate.

N-21

| INSPECTION REPORT | | | | |
|---|---|---|---|---|
| 1. | Name & address of the building | **J.B.M. Public School** located at Nasir Pur, New Delhi–110045 | | |
| 2. | Type of Occupancy | Educational (Group B-1) | | |
| 3. | Building Comprised of | Ground plus three upper floors. | | |
| 4. | Type of Case | Renewal/approval for the use of 3rd floor. | | |
| 5. | Details of previous NOC No. | F.6/DFS/MS/School/2023/SZ/191 Dt. 17/03/2023 | | |
| 6. | Fire safety directives letter No. | As per NBC Part-IV | | |
| 7. | Date of inspection | 27/05/2026 | | |
| 8. | Name of the Inspecting Officer | ADO (JKP) | | |
| 9. | Name and designation of Officer from the building side | Dr. Amit Solanki (Manager) | | |
| 10. | Year of Construction | 2002 & 2015 | | |
| 11. | Applicant's letter No. | Outdoor Diary No. 1372 dated 20/05/2026 | | |
| S. No. | Minimum standards on fire prevention and fire safety U/R 33 | NBC/UBBL Requirement | Provided at site | Remarks MR/NMR |
| 1. | Access of building | | | |
| | • Road width | 6.0 mtr | Provided | MR |
| | • Gate width | 4.5 mtr | Directly accessible from road | MR |
| | • Width of internal road | N/A | N/A | N/A |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 02 Nos | 04 Nos | MR |
| | • Basements | N/A | N/A | N/A |
| | b. Width of staircases | | | |
| | • Upper floors | 1.50 mtr | 2 x 1.5m, 1.25m, 1.20m & 1.50m ramp (GF to FF) | MR |
| | • Basements | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No of continuous staircase to terrace | 02 Nos | Provided | MR |
| | e. Width of Corridor | 1.5 mtr | Provided | MR |
| | f. Door Size | 1.0 mtr | Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire Rating of shaft door | N/A | N/A | N/A |
| | • Water Curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Managements System | | | |
| | • Basements | N/A | N/A | N/A |
| | • Upper floors | Required | Natural ventilation | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 10 Nos | 15 Nos | MR |
| | • Types | ABC/$CO_2$ | ABC & $CO_2$ | MR |
| | • ISI marking | ISI marked | Provided | MR |
| 6. | First–Aid Hose Reels | | | |
| | • Total numbers on each floor | 01 No. | 02 Nos | MR |
| | • Length of hose reel hose | 30 mtr | Provided | MR |
| | • Nozzle diameter | 5 mm | Provided | MR |

| | | | | |
|---|---|---|---|---|
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | N/A | N/A | N/A |
| | • Location of Main Panel | N/A | N/A | N/A |
| | • Location of Repeater Panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooters' Location | N/A | N/A | N/A |
| 8. | MOEFA | N/A | Provided | N/A |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | N/A | N/A | N/A |
| | • Upper Floor | N/A | N/A | N/A |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | N/A | 100 mm | N/A |
| | • Number of hydrants per floor | N/A | 02 Nos | N/A |
| | • Hose Box | N/A | Provided | N/A |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | • **Ground Level** | | | |
| | ➢ Discharge of main pump | N/A | N/A | N/A |
| | ➢ Head of main pump | N/A | N/A | N/A |
| | ➢ Number of main pumps | N/A | N/A | N/A |
| | ➢ Jockey pump out put | N/A | N/A | N/A |
| | ➢ Jockey pump head | N/A | N/A | N/A |
| | ➢ Standby Pump out put | N/A | N/A | N/A |
| | ➢ Standby Pump Head | N/A | N/A | N/A |
| | ➢ Auto Staring/Manual stopping | N/A | N/A | N/A |
| | ➢ Pump House Access | N/A | N/A | N/A |
| | • **Terrace level** | | | |
| | ➢ Discharge of pump | 450 LPM | Provided | MR |
| | ➢ Head of the pump | 40 mtr | Provided | MR |
| | ➢ Power supply | Required | Provided | MR |
| | ➢ Auto starting of pump | Required | Provided | MR |
| 14. | Captive water storage for firefighting | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➢ Draw of connection | N/A | N/A | N/A |
| | ➢ Fire service inlet | N/A | N/A | N/A |
| | ➢ Access to tank | N/A | N/A | N/A |
| | • Overhead Tank capacity | 10,000 ltrs | Provided | MR |
| 15. | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➢ Pressurization of Lift Shaft | N/A | N/A | N/A |
| | ➢ Pressurization of lift lobby | N/A | N/A | N/A |
| | ➢ Communication in lift Car | N/A | N/A | N/A |
| | ➢ Fireman's Grounding Switch | N/A | N/A | N/A |
| | ➢ Lift Signage | N/A | N/A | N/A |
| 17. | Standby Power Supply | N/A | N/A | N/A |
| 18. | Refuge Area | | | |
| | ➢ Total area | N/A | N/A | N/A |
| | ➢ Location | N/A | N/A | N/A |

N-23

| | | | | |
|---|---|---|---|---|
| 19. | Fire Control Room | | | |
| | ➢ Detector system panel | N/A | N/A | N/A |
| | ➢ Flow Switch Panel | N/A | N/A | N/A |
| | ➢ PA System Panel | N/A | N/A | N/A |
| | ➢ Battery backup | N/A | N/A | N/A |
| | ➢ Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection Systems for Protection of Special Risks, if any; | N/A | N/A | N/A |

The fire protection systems provided in the building/premises were checked, tested at random and **found functional at the time of inspection.**

In view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/School/2024/SZ/1175 dated 10/12/2024, **recommended for approval/renewal up to 3rd Floor under rule 37 of the Delhi Fire Service Rules, 2010.** FSC issued vide letter no. 1175 dated 10.12.24 shall stand null and void.

Accordingly, **DFA is put up for approval** & signature please.

29/5/26

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (JKP)

**DO (SW)**

29/5/26
RAJINDER ATWAL
CFO (SZ)

29/5/26
A.K. MALIK
Principal Director

CFO (SZ)
01/06/26

1/6/26
A.K. MALIK
DO (SW)

1/6
ADO (JKP)

P.T.O