आज़ादी का अमृत महोत्सव

C-10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/2026/ 814 Dated: 27 / 08 /2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in respect of M/s Jhol (A unit of House of Ten Hospitality LLP) located at Ground Floor, The Crescent Partial in Local shopping centre, Plot no-1 to 7, Lado Sarai, New Delhi-110030.

Sir,

Please refer to your online application ID No. 2026071209734 & 2026071209735 dated-12/07/2026, on the subject cited above. In this connection, it is to inform you that the premise was inspected by officer concerned of this department on 03/08/2026 in the presence of Sh. Akshay Kumar Shokeen to see the functioning of fire safety arrangements/equipments provided in the building. During inspection the following shortcomings were observed.

1. Door size width of 1.60 & 1.50m are provided against requirement of 2m and 1.5m respectively.
2. The address of the premises is not mentioned on the plan as uploaded in the portal.

In view of above, the application for issuance of Fire safety Certificate is cannot consider at this stage.

Yours faithfully,

27/8/26

(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier, M/s Jhol (A unit of House of Ten Hospitality LLP) located at Ground Floor, The Crescent Partial in Local shopping centre, Plot no-1 to 7, Lado Sarai, New Delhi-110030. (Online application No. 2026071209734 & 2026071209735 dated-12/07/2026).