c/16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/EH/NDZ/2026/ 400

Dated: 28/04/2026

To,

Sh. Yunus Khan,
Shop No. E-988 and 989,
Ground Floor, 100 FT Road,
Babarpur, Shahdara, Delhi-110032.

Subject: - Regarding issuance of Fire Safety Certificate in Jubilant Food works Ltd (Domino's Pizza, Eating House) located at Shop No. E-988 and 989, Ground Floor, 100 FT Road, Babarpur, Shahdara, Delhi-110032.

Sir,

With reference to your ID No. **2026040604362** dated 06/04/2026 on the subject cited above. In this connection, it this connection, the premises have been inspected by the officer concerned of this department on dated 14/04/2026 in the presence of Mr. Mayur Anand, Manager. The building is comprised of ground plus three upper floors but (Domino's Pizza, Eating House) located at ground floor only (shop no. E-988 and 989). The following shortcomings was observed during the time of inspection.

1. First-Aid -Hose Reels provided but not functional.
2. Internal Hydrants provided but not functional.
3. Pump not working in auto mode.

In view of above shortcomings, the application for issuance Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

28/4/26

(Dr. S. K TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

O/C

Copy to: -

The Commissioner, MCD, Civic Centre, New Delhi.
MCD ID No. **2026040604362.**