GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/EH/2025/EZ/ 403 Dated: 14/10/2025

To,

Sh. Yunus Khan,
M/s Jubliant Foodworks Limited Dominos Pizza,
Ground Floor, G-40, Vikas Cine Mall,
Shahdara, Delhi- 110032.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Jubliant Foodworks Limited Dominos Pizza located at Ground floor, G-40, Vikas Cine Mall, Shahdara, Delhi- 110032.

Sir,

This has reference to online application received through MCD portal vide ID-2025091113367 on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by officer concerned of this department on 22/09/2025 in presence of Mr. Mukesh (Manager) and observed that of the shortcomings issued by this department vide letter No.F6/DFS/MS/EH/2025/SZ/220 dated 19/05/2025 are still not complied (copy enclosed).

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

14/10/25

(Dr. S.K. Tomar)
Dy. Chief Fire Officer

Enclose: As above.

C-27

आज़ादी का अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2025/SZ/220 Dated: 19/05/2025

To

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Jubilant Food Works Ltd (Domino's Pizza) at Ground Floor, Shop No G-40, Vikas Cine Mall, Shahdara Delhi 110032.

Sir,

This has reference to your **MCD Portal ID 2025042407065 dated 24/04/2025** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 09.03.2025 in the presence of Ms. Nisha (Manager) to verify the fire safety measures installed in the building and observed that the building is comprised of 02 Basement, Ground plus 04 upper floors and restaurant is running at ground floor only. During inspection, following points were observed:

1 Terrace level fire fighting pumps capacity 450 LPM found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE