C-39

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2026/ 58 Dated: 20/01/2026

To,

The Commissioner,
Municipal Corporation of Delhi
Civic Center, New Delhi – 110002.

Subject: - Regarding Grant of Fire Safety Certificate in r/o **M/s Juggernauth** (A Unit of Gardens of Earth Private Limited located at HS – 16, Kailash Colony, New Delhi - 110048.

Sir,

Please refer to your MCD Portal application No. 2025122916214 dated 29/12/2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on 10/01/2026 in the presence of Mr. Vaibha Singh Chauhan (Owner) and observed that the shortcoming is still not complied with as issued by this department vide letter no. F6/DFS/MS/EH/2025/SZ/366 dated 30/08/2024 (copy overleaf).

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

20/1/26

A.K. Malik
Dy. Chief Fire Officer
Delhi Fire Service

O/C (W)

Enclosed: As above

आज़ादी का अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2024/SZ/366 Dated 30/08/2024

To

The Joint Commissioner of Police / Licensing,
1st floor, Police Station, Defence Colony,
New Delhi- 110049

Sub: - Regarding issuance of fire safety certificate in r/o **M/s Juggernauth** (A Unit of Gardens of Earth Pvt. Ltd.), HS-16, Kailash Colony, New Delhi-110048.

Sir,

This has reference to with **MHA Portal ID 2024080612279 Dated: 06.08.2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.08.2024 in the presence of Mr. Shyam to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. There are only one staircase width of 1.0m against the requirement of two staircase having width of 1.50 mtr each.
2. There are two exit door having width of 2.0 mtr & 1.0 mtr provided against the required width of 1.50 mtr each.
3. First aid hose reel found removed.
4. Automatic Detector system not provided
5. MOEFA system not provided.
6. Internal hydrant not provided.
7. Main electrical fire pump capacity of 2280 lpm & Diesel pumps capacity of 2280 lpm and jockey pump capacity 180 lpm not provided. Terrace level fire fighting pump capacity 450 lpm not provided.
8. Underground tank capacity 1, 00,000 ltrs not provided.
9. Overhead water storage tank capacity 10,000 ltrs not provided.
10. Exit Signage not provided in the building.
11. Standby power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE