**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001**

No. F.6/DFS/MS/School/2026/EZ/ 688 Dated: 17 / 07 /2026

To

The Manager,
K.G. Aggarwal Public School,
C–1/7A, Yamuna Vihar,
Delhi–110053

Sub: **Regarding renewal of Fire Safety Certificate in r/o K.G. Aggarwal Public School located at C–1/7A, Yamuna Vihar, Delhi–110053**

Sir,

This has reference to online application No. **52026062503973** on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 07/07/2026 in the presence of Ms. Sakshi Raj (Receptionist) to verify the compliance of fire safety measures required under the rules. During course of inspection, the observations made are as below.

1. Only single staircase of 0.90m is found provided and the second staircase of 1.5m as seen during previous inspection found removed.
2. Hose-reel hose provided found non-functional.
3. Terrace fire pump found non-functional.

In view of the above, application for renewal of fire safety certificate cannot be considered at this stage & rejected. You are directed to rectify and submit compliance the above-mentioned shortcomings for further action in the matter.

Yours faithfully,

16/7/26

**(Dr. S. K. TOMAR)**
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi–110053