c/98

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 184 Dated: 27/02/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Kaka Guest House, 3440, Dirba Pan, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026021201527 dated 12/02/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 17/02/2026 in the presence of Mr. Irshad Ali, Manager and following shortcomings were observed: -

1. Hose reel provided but found damaged.
2. Automatic operation of Fire pump found removed.
3. Carbon Monoxide detectors found removed at some places.
4. Domestic connection in overhead water storage tank is not permitted.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

26/2/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

O/C BR

Copy to: -

1. The Manager, M/s Kaka Guest House, 3440, Dirba Pan, Paharganj, New Delhi - 110055.