GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F.6/DFS/MS/WZ/2026/155 Dated: 28/04/2026

To,

The Authorized Signatory,
Kalra Hospital SRCNC Pvt. Ltd.,
A-7, Tulsi Dass Kalra Marg, Kiriti Nagar,
New Delhi-110015

Subject: - Regarding issuance of Fire Safety Certificate in r/o Kalra Hospital SRCNC Pvt. Ltd. Located at A-7, Tulsi Dass Kalra Marg, Kiriti Nagar, New Delhi-110015.

Sir,

Please refer to your letter no. nil dated nil received through outdoor diary no. 12140 dated 25/03/2026, on the subject cited above, in this connection, this is to inform you that the above mentioned premises was visited by the officer concerned of this department on dated 06/04/2026 in the presence of Dr. Baldev Batra to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations: -

1. Pressurization of lift shaft and lift lobby are not provided in basement & upper floors.
2. The Door schedule of patient room, general ward and ICU are not as per the required width UBBL – 2016. Single door having width of less than 2 m is provided in the general ward /ICU against the requirement of two doors.
3. Smoke management system not provided in basement and upper floors.

In view of above shortcomings, the case for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

28/04/26

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic Center, New Delhi.
2. The MS, Nursing Home Cell, DGHS, Govt. of NCT of Delhi, S-1, 3rd floor, School Block, Shakarpur, Delhi-110092.