आज़ादी का अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/SZ/2026/405 Dated: 29/04/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in r/o. M/s. Kampai (A Unit of Mizunara Hospitality LLP), located at Shop No.308, Second Floor, DLF Promenade, Vasant Kunj, New Delhi-110070.

Sir,

Please refer to your online application no. No. 2026040304223 dated-03/04/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 23/04/2026 in the presence of Ms. Avantika Sinha to see the functioning of fire safety Equipments provided in the building.

During inspection, it has been observed that the said eating house is running at. Second Floor only, in DLF Promenade Mall comprised of Two Tiers, Basement + Lower Ground + Upper Ground + First Floor & Second Floor (Projection Room). Fire safety arrangements such as Fire Extinguishers, MOEFA etc. provided. However, the following shortcomings were observed.

1. MOEFA is provided but not integrated with Mall.
2. Exit Signage's are found removed.
3. Further, as built plan of the establishment is also not uploaded in the portal.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is cannot considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,

29/4/26

(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier, M/s. Kampai (A Unit of Mizunara Hospitality LLP), located at Shop No.308, Second Floor, DLF Promenade, Vasant Kunj, New Delhi-110070. Online application No. 2026040304223 dated-03/04/2026).