GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/Banqt/NDZ/2026/ 517 Dated :02./.06./2026

FIRE SAFETY CERTIFICATE

Certified that the **M/s Kanishka Banquet located at Property No. D 35-36, Main Road Kanti Nagar, Delhi-110051** in a building comprises of Basement+ Ground+ 02 Upper floors (Banquet Hall is running at Ground+ 01 Upper floor only) was earlier issued FSC by this department vide letter No. F.6/DFS/MS/BNQT/2023/43 dated 01/11/2023. Now, the premises was re-inspected by the officer concerned of this department on 22/05/2026 in the presence of Sh. Dinesh Gupta (Owner) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises (**Ground + 01 upper floor only**) is fit for occupancy class **"Assembly Building (Banquet)" Group - D** with effect from 02/06/ 2026 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....02/06/2026.....at New Delhi by.

1/6/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi. (MCD Online ID. 20260051206741 dated 12/05/2026)
2. Sh. Dinesh Gupta (Owner), M/s Kanishka Banquet located at Property No. D 35-36, Main Road Kanti Nagar, Delhi-110051.

Conditions for the validity of Fire Safety Certificate: -

1. The FSC is issued for Ground + 01 upper floor only.
2. All the fire safety arrangements provided therein shall be always maintained in good working conditions.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified by the authority concerned.
6. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any. Basement shall be used as per BBL concerned.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

N/26

INSPECTION REPORT

1.	Name & address of the building	**M/s Kanishka Banquet located at Property No. D 35-36, Main Road Kanti Nagar, Delhi-110051.**		
2.	Building Comprised of	Basement+ Ground+ 02 Upper floors. (Banquet Hall is running at Ground+ 01 Upper floor only)		
3.	Type of occupancy	Assembly Building (Banquet Hall), "Group D"		
4.	Type of case	Renewal		
5.	Details of previous FSC No.	F.6/DFS/MS/BNQT/2023/43 dated 01/11/2023		
6.	Fire safety directives No.-	F6/DFS/MS/BP/2013/877 dated 01.03.2013		
7.	Date of inspection: -	22/05/2026		
8.	Name of the inspecting officer: -	Nitin Lohchab, ADO (Shahd.)		
9.	Name & designation of officer from the building side: -	Sh. Dinesh Gupta (Owner)		
10.	Year of construction: -	2010		
11.	Applicant's letter No: -	Online Portal Application ID - 20260051206741 dated 12/05/2026		
S. No	**Minimum Standards on fire Prevention and Fire Safety U/R 33**	**Requirements as per directives**	**Provided at site**	**Remarks MR/NMR**
1.	**Access to Building**			
	• Road width	06 m	06.10 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	**Number, Width Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper floors	02nos.	02nos.	M/R
	• Basements	N/A	N/A	N/A
	b. Width of staircase			
	• Upper floors	1.50 mtr	1.50 mtr and 1.35 mtr	MR (being old case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01 no.	01 no.	M/R
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	02 mtr	2.0 mtr & 1.70 mtrs	MR (being old case)
3.	**Compartmentation**			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	**Smoke Management System**			
	• Basements	NA	NA	NA
	• Upper floors// Ground floor	Required	Provided	MR
5.	**Fire Extinguishers**			
	• Total numbers	10 nos.	12 nos.	MR
	• Types	ABC /CO_2	ABC /CO_2	MR
	• ISI marking	ISI marked	ISI marked	MR
6.	**First-Aid Hose Reel**			
	• Total number of each floor	01 no.	Provided	MR
	• Length of hose reel hose	30 mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

7.	**Automatic Fire Detection & Alarming System.**			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's Location	N/A	N/A	N/A
8.	**MOEFA**	Required	Provided	MR
9.	**Public Address System**	N/A	N/A	N/A
10.	**Automatic Sprinkler System**			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants**			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose box per floor	01	Provided	MR
12.	**Yard Hydrants**			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13.	**Pumping Arrangement**			
	Ground level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Stand by pump output	N/A	N/A	N/A
	• Stand by pump head	N/A	N/A	N/A
	• Auto starting/Manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	Terrace level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	**Captive Water Storage for Fire Fighting**			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	15,000 ltrs	15,000 ltrs	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	N/A	N/A	N/A
	• Lift signage	NA	NA	NA

N/28

17.	**Stand by Power Supply**	Required	Provided	MR
18.	**Refuge Area**			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	**Fire Control Room**			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	**Special Fire Protection System for Protection of special Risk, if any:**	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked randomly and found functional at the time of inspection. The shortcomings communicated by this department vide letter No. F.6/DFS/MS/Bnqt/NDZ/2026/336 dated 16/04/2026 have been complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules. The NOC/FSC was issued vide letter No. F.6/DFS/MS/BNQT/2023/43 dated 01/11/2023 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Last date: **10/06/2026.**

Accordingly, **DFA** is prepared and put up for kind perusal and approval please.

25/5/26

Signature of the Inspecting Officer
Name: - Nitin Lohchab
Designation: - ADO (Shad.)

DO (ED) 26/5/26

CFO (NDZ)

27/5/26

Principal Director

CFO to Director.

26/5/26

CFO (NDZ)

27/5/26

ADO/SHAH

F.T letter is put up for your kind perusal & signature please.

CFO (NDZ)

1/6/26

01/6/26

M/s Kanishka Banquet located at Property No. D 35-36, Main Road Kanti Nagar, Delhi-110051

MS

02/6/26