GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2026/School/ 392 Dated: 27/04/2026

To,

Mrs. Punam (In-Charge),
Kapila Public School,
2, Sandesh Vihar, Pitampura,
Delhi-110034.

Sub: Issue of FSC in r/o M/s Kapila Public School, 2, Sandesh Vihar, Pitampura, Delhi-110034.

Sir,

Kindly refer to the letter received in this department vide Outdoor Diary No. 11294 dated 24.02.2026 on the subject cited above. In this connection, it is informed that the above-mentioned building was inspected by the officers concerned of this department on 21.04.2026 in the presence of Mrs. Punam (In-Charge). During the inspection, it was observed that the building comprises Ground plus two upper floors, and the school is operating on the first and second floors only.

The point-wise status is as under:–

Sr. No.	Shortcomings	Remarks
1.	One additional staircase having width at least 0.75m is required	**(Not rectified)** Provided but accessible through class room
2.	Terrace pump is provided but not functional.	**Not complied**
3.	Hose reel is provided but not functional	**Not complied**
4.	Capacity of overhead water tank is less than required capacity of 2500ltr	**Not complied**

Yours faithfully

27/04/26

(S.K.Dua)
Chief Fire Officer
Delhi Fire Service