c/26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2025/School/ 813 Dated: 17 / 11 /2025

To

The Chairmen
Karan Public School,
B-312, Aman Vihar, Kirari, Delhi-86.

Sub: Regarding issuance of fire safety certificate in r/o Karan Public School at B-312, Aman Vihar, Kirari, Delhi-110086.

Sir,

Please refer to your letter received through online e-mail dated 08/09/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 03/11/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 03 upper floors only. At the time of inspection Sh. Bhupender (Chairman) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Terrace level fire pump not in auto mode.
2. Terrace level fire water tank capacity of 8,000 Ltr is provided against the requirement of 10,000 Ltr and terrace level fire water tank interconnected with 1 inch pipe line required replace by 3 inch line.
3. Exits & floor level marking found removed at some places.
4. Standby power supply is not provided.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

14/11/25

(S.K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi – 110085.