c/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DLEHI - 110 001

No. F.6/DFS/MS/WZ/EH/2026/ 416 Dated: 05/05/2026

To,

Mr. Amit Kataria,
House No.H-238, 3rd floor,
Phase-1, Ashok Vihar,
Delhi-110052.

Sub: Renewal of FSC in r/o M/s Kesar (A unit of AGS Hospitality) Plot No.11, Gr. & 1st floor, Community Centre, Phase-2, Delhi-110052.

Sir,

This isrefer to online application no. 2026040804612 dated 10.04.2026, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 20.04.2026, in presence of Mr. Yadav to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. First Aid hose reel provided but found not functional.
2. Terrace level Fire Fighting pump with capacity of 450LPM provided but not functional.
3. Manually operated electric fire alarm provided but not functional.
4. Terrace fire water tank capacity was found to be less than 20,000 liters.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

30/04/26

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy To:-

1. MCD Portal Id- 2026040804612 dated 10.04.2026.