Azadi Ka Amrit Mahotsav

C-36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F6/DFS/MS/2025/WEST ZONE/ 09 Dated 05/01/2026

To,

The Commissioner (MCD),
SPM Civic Centre,
JL Nehru Marg, Delhi-110002

Sub:- Special Drive for surprise inspection in r/o eating houses / restaurants in Delhi from Fire prevention & Fire Safety point of view.

Sir,

As per the office order No. F6/DFS/HQ/2025/2127 dated 10/12/2025, surprise inspection of eating house namely **Kibou (A unit of ASA Hospitality) located at Third Floor, Property No-6, B-Block, Gujrawala Town Part-I, Delhi-110009** was conducted by officer of this department on dated 20/12/2025 in the presence of Sh. Prince (Manager) to ascertain the availability & operability of the Fire prevention & Fire Safety measure provided in the building and following observation were made during the time of inspection.

1. Fire Pumps i.e. 2280LPM(E), 2280LPM(D), 180LPM (Jockey pump) & 450LPM (Terrace Pump) capacity were provided but found nonfunctional.
2. Hose reel hose provided but found nonfunctional.
3. Hoses / Hose boxes also found removed.

The above-mentioned shortcomings should be complied latest by 7 days (i.e.27/12/2025).

Keeping in view of above, Fire Safety Certificate issued by this department vide letter F6/DFS/MS/EH/2024/EH/325 Dated 11/10/2024 to the **restaurant will remain suspended** until the compliance of the above mentioned shortcomings. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully

05/01/26
(S.K. Dua)
Dy. Chief Fire Officer (WZ)

Copy to:-

1. Sh. Prince (Manager), Kibou (A unit of ASA Hospitality), Third Floor, Property No-6, B-Block, Gujrawala Town Part-I, Delhi-110009.