GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F6/DFS/MS/WZ/2026/120

Dated: 17/04/2026

To,

The Medical Superintendent,
Konarc Hospital,
9A/1, Naresh Park, Main Najafgarh Road,
Nangloi, Delhi – 110041

Sub: - Surprise inspection report in r/o M/s Konarc Hospital located at 9A/1, Naresh Park, Main Najafgarh Road, Nangloi, Delhi – 110041.

Sir,

As per directions of the Competent Authority vide office order no. F6/DFS/HQ/2026/494 dated 20/03/2026, it is to inform you that the surprise inspection of above said Hospital building has been carried out by the officer concerned on 02.04.2026 to verify the compliance of the requisite fire safety measures installed in the building in the presence of Mr. Neeraj Sharma (Manager) was present at the time of inspection. During the visit of the following observation were noticed:-

1. Smoke management system in basement found provided but not functional.
2. Hose reel nozzle found missing at some places.
3. Detectors found provided but not functional at some places.
4. Pumping system not found in auto mode.
5. Exit Signage found removed at some places.

You are advised to rectify the above-mentioned shortcoming under intimation to this department, till than the occupancy of the Building/ Premise in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours Faithfully

15/04/26

S.K. Dua
Chief Fire Officer
Delhi Fire Service