आज़ादी का अमृत महोत्सव

C-14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/GH/SZ/2026/ 817 Dated: 27/08/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of Fire Safety Certificate in r/o. M/s. Hotel located at L-16, kalkaji, New Delhi-110019.

Sir,

Please refer to your online application no. No. 2026080410290 dated- 04/08/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 13/08/2026 in the presence of Dr Amit Gupta (Owner) to see the functioning of fire safety arrangements/equipment's provided in the building. During the inspection, the following shortcomings were observed.

1. Width of corridors is 1.2m provided against the requirement of 1.8m.
2. Final exits of width 1.2m are provided against the requirement of 1.5m each.
3. First Aid Hose reels & Hydrents are provided but not functional
4. MOEFA is provided but not functional.
5. Terrace pump capacity of 450 LPM, is not provided.
6. Fire Check doors are not provided.
7. Over Head water storage tank capacity of 5000ltrs provided against the requirement of 10,000ltrs.
8. Exit Signage are not provided.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is cannot considered at this stage & rejected.

Yours faithfully,

27/8/26.

(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier M/s Hotel located at L-16, kalkaji, New Delhi-110019. (Online application No. 2026080410290 dated- 04/08/2026).