GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/BANQUET/SZ/2026/138 Dated 17/02/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o L' Elegant The Royal Banquet (A Unit of Khan & Sirohi Electro Mechanical) located at Khasra No. 463 & 464, Kalindi Kunj Park, Okhla, New Delhi – 110024.

Sir,

This has a reference to MHA application No. 2026012200810 dated 24/01/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 03/02/2026 in the presence of Mr. Imran Ali Khan and observed that building comprised of ground plus one upper floor, Banquet Hall running on ground floor only & 1st floor use for offices (Independent entry /exit).

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel provided but not functional.
2. MOEFA provided but not functional.
3. Internal Hydrants provided but not functional.
4. Terrace fire pump provided but not functional.
5. Overhead tank of 15,000 liters capacity is provided against the requirement of 20,000 liters
6. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

M. K Chattopadhyay
Dy. Chief Fire Officer
Delhi Fire Service