**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/BNQT/NDZ/2026/ 132

Dated: 13/02/26

To

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Lado Rani (A Unit of Rajni LC Hospitality Private Limited) located at Property no. 44, Ground floor, Hasanpur, Shahdara, New Delhi.

Sir,

With reference to the etl.mcdonline application no. 2026011200396 on the subject cited above, it is informed that the said Banquet Hall was inspected by officer concerned of this department on 10/02/2026 in the presence of Mr. Lalit Chauhan (Owner o the Banquet Hall) and following shortcomings were observed: -

1. Fire check doors found removed.
2. Manuel Operated Electrical Fire Alarm (MOEFA) system found non functional.
3. All water based systems like Hose Reel, Down Comer System & Terrace fire pump are found non functional.
4. The combustible furnishing at rear exit must be removed.
5. Auto starting of fire pump found removed.
6. An additional terrace water tank of 5000 litres shall be provided to meet the total requirement of 25000 litres terrace water tank capacity.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

13/2/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

o/c