GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/Audi/ECN/2026/142 Dated :09/07/2026

FIRE SAFETY CERTIFICATE

Certified that **Auditorium** at **Lady Hardinge Medical College, New Delhi** comprised of Basement, Ground & 01 Upper Floor was earlier granted Fire Safety Certificate by this department vide letter No. **F6/DFS/MS/NDZ/Audi/2022/260 dated 14.06.2022**. Now, the premises was re-inspected by the officers concerned of this department on **23/04/2026** in the presence of **Sh. Shyam Mishra, J.E. (Electrical) CPWD** and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class – **Assembly Occupancy (Group – D)** with effect from 09/07/2026 for period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 09/07/2026 at New Delhi by.

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Chairman, NDMC, Palika Kendra, New Delhi – 110001.
2. The Executive Engineer, CPWD, Lady Hardinge Medical College and Associate Hospital, New Delhi – 110001.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT				
1.	Name & address of the building	Auditorium at Lady Hardinge Medical College, New Delhi.		
2.	Type of occupancy	Assembly Building (Auditorium)		
3.	Building comprised of:	Basement, Ground & 01 Upper Floor.		
4.	Type of case	**Renewal**		
5.	Details of previous FSC No.	F6/DFS/MS/NDZ/Audi/2022/260 dated 14.06.2022		
6.	Fire safety directives No.-	N/A		
7.	Date of inspection: -	23/04/2026		
8.	Name of the inspecting officer: -	Sh. Manish Kumar, DO(CD) Sh. Bhupender Prakash, ADO(CC)		
9.	Name & designation of officer From the building side: -	Sh. Shyam Mishra, J.E. (Electrical) CPWD		
10.	Year of construction: -	1986		
11.	Applicant's letter No: -	DFS Online Portal ID: - 52025122400908 dated 09.03.2026		
S. No.	**Minimum Standards on fire Prevention and fire safety U/R 33**	**Requirement Existing**	**Provided at site**	**Remarks MR/NMR**
1.	**Access to Building**			
	• Road width	9.00 mtr.	9.00 mtr.	MR
	• Gate width	6.00 mtr.	6.00 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
2.	**Number, Width Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper floors	02 nos.	02 nos.	MR
	• Basements	02 nos.	03 nos.	MR
	b. Width of staircase			
	• Upper floors	1.00 mtr.	1.14 mtr. each	MR
	• Basements	1.00 mtr.	02 X 1.14 mtr. 01 X 1.20 mtr.	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2.00 mtr.	2.00 mtr.	MR
3.	**Compartmentation**			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	**Smoke Management System**			
	• Basements	Required	Provided Exhaust Fan	MR
	• Upper floors	Required	Provided Natural	MR
5.	**Fire Extinguishers**			
	• Total numbers	10 nos.	12 nos.	MR
	• Types	ABC & CO_2	ABC, CO_2 & W.CO_2	MR

7.	**Automatic Fire Detection & Alarming System.**			
	• Type of detectors	Smoke/Beam	Provided	MR
	• Location of main panel	Ground	Provided	MR
	• Location of repeater panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's Location	Required	Provided	MR
8.	**MOEFA**	Required	Provided	MR
9.	**Public Address System**	Required	Provided	MR
10.	**Automatic Sprinkler System**			
	• Basement	Required	Provided	MR
	• Upper floors (Stage)	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants**			
	• Size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	02 nos.	02 nos.	MR
	• Hose box per floor	02 nos.	02 nos.	MR
12.	**Yard Hydrants**			
	• Total number of hydrants	02 nos.	02 nos.	MR
	• Hose box	02 nos.	02 nos.	MR
13.	**Pumping Arrangement**			
	Ground level	**Common Fire Pump of Main Building**		
	• Discharge of main pump	2850 LPM	2850 LPM	MR
	• Head of main pump	90 mtr	90 mtr	MR
	• Number of main pumps	02 nos.	02 nos.	MR
	• Jockey pump out put	200 LPM	200 LPM	MR
	• Jockey pump head	80 mtr	80 mtr	MR
	• Stand by pump output	2850 LPM	2850 LPM	MR
	• Stand by pump head	90 mtr.	90 mtr.	MR
	• Auto starting/Manual stopping	Required	Provided	MR
	Terrace level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14.	**Captive Water Storage for Fire Fighting (U/G Tank Common)**			
	• Underground tank capacity	1,00,000 Ltrs	2,00,000 Ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	N/A	N/A	N/A
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

19.	**Fire Control Room**			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	**Special Fire Protection System for Protection of special Risk, if any:**			N/A

*PNF – Provided but Non-Functional, *MR – Meeting Requirement, *NMR – Not Meeting Requirement

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to renew the FSC issued vide letter No. F6/DFS/MS/NDZ/Audi/2022/260 dated 14.06.2022 under Rule 35(6) of Delhi Fire Service Rules, 2010.

Accordingly, **DFA** is prepared and put up for perusal, approval and signature please.

23/06/26

Manish Kumar
DO (CD)

B Prakash 23/6/2026

Bhupender Prakash
ADO (CC)

CFO (ECH)

29/6/26

Principal Director

Cfo to issue.

2/7

CFO (ECH)

3/7/26

ADO/CC

As approved, F.T. letter is put up for signature pls

B Prakash 06/7/2026

CFO (ECH)