आज़ादी का अमृत महोत्सव

C-117

GOVERNMENT OF NATIONAL CAPITAL TERRITOTY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2026/NZ/796 Dated: 24/.08./2026

To

The Commissioner,
Municipal Corporation of Delhi,
E-1, 9th Floor, Dr. SPM Civic Centre, Minto Road,
New Delhi–110002
Email ID commissioner@mcd.nic.in

Sub: Regarding issuance of FSC in r/o M/s Lagoona Emerald Banquet located at Property No 13, G.F., Wazirpur Printing Press Area, Behind Punjab Kesari, Building, Delhi-110035.

Sir,

This has reference with **MCD Portal ID 2026061708965 Dated 30/07/2026** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 11/08/2026 in the presence of Mr. Mohan Parkash Gupta to see the compliance of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations: -

1. Fire check door found removed.
2. 01 No. of First aid hose reel found removed.
3. Terrace level pumps capacity 900 LPM not found in auto mode.
4. Exit signage found removed.
5. 02 Rooms at terrace has to be removed or to be regularized from the building sanctioning authority.

In view of above Shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

24/8/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service