C 32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS /EH /NZ/2026/ 718 Dated 09/09/2026

FIRE SAFETY CERTIFICATE

Certified that M/s Lala Shivnath Rai Sumerchand Confectioner Pvt. Ltd. located at Shop No. 5, Ground Floor, Vaishali Main Road No. 41, Delhi- 110034 is running at Ground floor in a building comprised of Basement, Ground plus Three upper floors have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 21.08.2026 in the presence of Mr. Aditya and found that the building/ premises is fit for occupancy " Assembly " (Group D) Restaurant at Ground floor only with effect from 09/09/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on ....09/09/2026 at New Delhi by

8/9/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Delhi: - to ensure the occupancy as detailed above and deviation if any. Ref: (MCD Portal ID No. 2026081210434).
2. Owner/ Occupier of M/s Lala Shivnath Rai Sumerchand Confectioner Pvt. Ltd. located at Shop No. 5, Ground Floor, Vaishali Main Road No. 41, Delhi- 110034.

Conditions for the validity of Fire Safety Certificate:

1. Fire Safety Certificate is valid for Ground only.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to nonfunctional fire safety measure shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MCD portal (https://www.mcdonline.nic.in) along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **www.dfs.delhigovt.nic.in**
9. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
10. Basement shall be used as per BBL.

INSPECTION REPORT

1. Name & address of the building : M/s Shivnath Rai Sumerchand Confectioner Pvt. Ltd. Located at Shop No. 5, Ground Floor, Vaishali Main Road No. 41, Delhi- 110034
2. Type of Occupancy : Assembly (Restaurant)
3. Building Comprised of : Basement, Ground plus three upper floors **(Restaurant is running at Ground floor only)**
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : NBC Part- IV/ UBBL
7. Date of inspection : 21/08/2026
8. Name of Inspecting Officer : R.K.Sinha, ADO (Shalimar Bagh)
9. Name and designation of officers From the building side : Mr. Aditya
10. Year of Construction : 1998 as per MCD portal
11. Applicant's letter No. : MCD Portal ID No. 2026081210434 dated 12/08/2026

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV/ UBBL	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	6 m	Provided	MR
	• Gate width	5 m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.5 m each x 2	Provided	MR
3.	**Compartmentation**			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	**Smoke Management System**			
	• Basements	NA	NA	NA
	• Ground floor	Required	Provided	MR
5.	**Fire Extinguishers**			
	• Total numbers	1 @ 300 sqm	Provided	MR
	• Types	ABC/Co2 Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	**First-Aid Hose Reels**			

	• Total numbers on each floor	01	Provided		M
	• Length of hose reel hose	30 m	Provided		MR
	• Nozzle diameter	5 mm	Provided		MR
7.	**Automatic fire detection and alarming system**				
	• Type of detectors	NA	NA		NA
	• Location of Main Panel	NA	NA		NA
	• Location of Repeater Panel	NA	NA		NA
	• Alternate source of power	NA	NA		NA
	• Hooters' Location	NA	NA		NA
8.	**MOEFA**	Required	Provided		MR
9.	**Public Address System**	NA	NA		NA
10.	**Automatic Sprinkler System**				
	• Basement	NA	NA		NA
	• Ground Floor	NA	Provided		NA
	• Sprinkler above false ceiling	NA	NA		NA
11.	**Internal Hydrants**				
	• Size of riser/down-comer	100 mm	Provided		MR
	• Number of hydrants per floor	01	Provided		MR
	• Hose Box	01	Provided		MR
12.	**Yard Hydrants**				
	• Total number of hydrants	NA	NA		NA
	• Hose Box	NA	NA		NA
13.	**Pumping Arrangements**				
	• Ground Level				
	➢ Discharge of main Pump	NA	NA		NA
	➢ Head of Main pump	NA	NA		NA
	➢ Number of main pumps	NA	NA		NA
	➢ Jockey Pump out put	NA	NA		NA
	➢ Jockey pump head	NA	NA		NA
	➢ Standby Pump out put	NA	NA		NA
	➢ Standby Pump Head	NA	NA		NA
	➢ Auto Starting/Manual Stopping	NA	NA		NA
	➢ Power Supply	NA	NA		NA
	• Terrace level				
	➢ Discharge of pump	450 lpm	Provided		MR
	➢ Head of the pump	40 m	Provided		MR
	➢ Power Supply	Required	Provided		MR
	➢ Auto Starting of pump	Required	Provided		MR
14.	**Captive Water Storage for fire fighting**				

N-16

	• Underground tank capacity	NA	NA	NA
	➢ Draw-off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	**Standby power supply**	Required	Provided	MR
18.	**Refuge Area.**			
	➢ Total Area	NA	NA	NA
	➢ Location	NA	NA	NA
19.	**Fire Control Room**			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	**Special Fire Protection System for Protection of special Risks, if any:**	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter no. F-6/DFS/MS/EH/NZ/2026/755 dated 05.08.2026

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to grant fire safety certificate under Rule 35 of the Delhi Fire Service Rules, 2010.

Deemed Approved After 10/09/2026

ADO(S.B)
24/8/26

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/Sahlimar Bagh

DO/CND Oh leave

CFO (NZ) Pl. speak reg shortcomings issued earlier
25/8/26

ADO(SB) Sir. Shortcomings Communication vide letter dated 5/8/26 have been complied.
ADO(SB)
25/8/26

CFO(NZ)
25/8/26

Principal Director CFO for CFO (F-6) ADO(SB)
7/9/26