C-165

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/NW/2026/BNQT./ 691 Dated: 17/07/2026

To,

The Commissioner,
MCD, Civic Centre, Minto Road,
New Delhi-110002.

Sub: Renewal of FSC in r/o M/s Bonlon The Legend (A unit of Delicious Coco Water Pvt. Ltd.) located at D-13, Gr. 1st & 2nd floor, Udyog Nagar Industrial Area, Udyog Nagar, Delhi-110041.

Sir,

This has reference to online application no. 2026060207871 dated 03.06.2026 on the subject cited above. In this connection, it is to inform you that the above said building was re-inspected by the officer concerned of this department on 20.06.2026 in the presence of Mr. Neeraj to check the compliance of shortcomings issued by this department vide letter no. F.6/DFS/MS/BNQT/2026/WZ/460 dated 13.05.2026 (copy enclosed).

During inspection, it has been observed that the shortcomings issued by this department vide above said letter has not been rectified yet.

In view of the above, the application for renewal of Fire Safety Certificate cannot be considered at this stage & **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

16/07/26

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Enclosed: - As above

Copy to:-

1. MCD Portal ID-2026060207871 dated 03.06.2026.

C-16 4
C-157

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/BNQT/2026/WZ/460 Dated: 13/05/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Bonlon The Legend (A Unit of Delicious Coco Water Pvt. Ltd.) located at D-13, Udyog Nagar, Industrial Area, New Rohtak Road, Delhi-110041.

Sir,

This has reference to your online application received through MCD Portal ID No. 2026041505050 dated 15/04/2026 on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by the officer concerned of this department on 28/04/2026 in presence of Mr. Pawan. Following shortcoming were observed at the time of inspection.

1. Fire check door found removed at some places and some fire check doors needs to be repaired.
2. Smoke management system in basement found removed.
3. Detectors found removed at some places.
4. MOEFA found provided but not functional.
5. Entire pumping system not found in auto mode.
6. Exit signage's found removed at some places.
7. Electrical panel inside the staircase needs to be either removed or segregated with a fire check door.
8. Temporary structure at terrace floor found used as kitchen has to be removed/ dismantled.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

12/05/26

(S.K Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. MCD Portal ID No. 2026041505050 dated 15/04/2026.