GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/SZ/2026/ 194 Dated 03/03/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Le Tresor Guest House (Om Garcia Hospitality Private Limited) located at Plot No. 132, Pocket – I, Jasola, Behind Apollo Hospital, New Delhi – 110025.

Sir,

This has a reference to MHA application No. 2025082112722 dated 09/02/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 22/02/2026 in the presence of Mr. Chander Kumar (Manager) and observed that building comprised of Basement + Stilt + Ground plus three uppers, following shortcomings were observed during time of inspection:

1. Smoke management System provided but not functional.
2. First-Aid-Hose Reel provided but not functional.
3. Carbon Monoxide detectors found removed.
4. Terrace fire pump provided but not functional.
5. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

3/3/26

A. K. Malik
Dy. Chief Fire Officer
Delhi Fire Service