GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52025121900788

Dated: 11-09-2026

SHORTCOMING(S)

With reference to your application ID **52025121900788** dated **11-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Little Academy School** at **A-155, Kondli, Gautam Gali, P.O. Vasundhara Enclave, Delhi - 110096** from fire safety point of view in presence of **Sh. Vijender Singh, Manager** on dated **22/08/2026** During the course of inspection following observations were made:-

1. Hose Reels is not provided.
2. Terrace fire pump of 450 lpm with 35 meters is head not provided.
3. Terrace Tank of 10000 litres is not provided.
4. Exit signages are not provided.
5. There is no provision of standby power supply.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-
1. SHAKUNTLA SINGH , A-155, GAUTAM GALI, KONDLI COLONY, DELHI, 110096
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.