GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6 /DFS/MS/Mercantile/SZ/2022/39 Dated: 10/02/2026

To

The Authorized Signature,
Living Style Mall (Fast Track Realcon)
Pocket – 6, Main Kalindi Kunj Road,
Jasola, New Delhi - 110025.

Subject: - Regarding grant of Fire Safety Certificate in r/o Living Style Mall (Fast Track Realcon) located at Pocket – 6, Main Kalindi Kunj Road, Jasola, New Delhi - 110025.

Sir,

This has a reference to your Outdoor Dairy No. 8385 dated 17.11.2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 27/01/2026 in the presence of Mr. Gaurav (Manager) and observed that building comprised of Basement, Ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. Fire Check door provided but door closed and panic bar found removed.
2. Smoke Management System provided but not functional.
3. Fire extinguishers provided but found empty.
4. First-Aid-Hose Reel provided but not functional.
5. MOEFA provided but not functional.
6. Internal Hydrants provided but not functional.
7. Pumping's Arrangements provided but not functional.
8. Exit & floors Signage's not provided at strategic location in the building.
9. Lifts Signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

9/2/26

A.K. Malik
Dy. Chief Fire Officer
Delhi Fire Service
O/C @

Copy to: -

1. The Executive Engineer, (Bldg), S.D.M.C, Jal Vihar, Lajpat Nagar – IV, New Delhi – 110024.