C-86

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F.6/DFS/MS/NDZ/EH/2025/02 Dated: 02 / 01 / 2026

To

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s London Street, SG-33,34,35,55,56,57, Aditya Mega Mall, CBD Shahdara Delhi-110032

Sir,

Please refer to online application No. 2025113015273 dated 30/11/2025 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 25/12/2025 in the presence of Sh. Dhreej, Manager and following shortcomings were observed: -

1. Fire check door is not provided at kitchen.
2. First aid Hose reel found non- functional.
3. MOEFA found non-functional.
4. Terrace pump found non-functional.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stand **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

1/1/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Manager, M/s London Street, SG - 33,34,35,55,56,57, Aditya Mega Mall, CBD Shahdara Delhi-110032.