आज़ादी का अमृत महोत्सव

C69

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/2026/ 766 Dated: / 07/08 /2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in respect of M/s. Kalsang Restaurant Private Limited located at M-30 First Floor, M-Block Market, Greater Kailash Part-2, New Delhi-110048.

Sir,

Please refer to your online applications vide ID No. 2026061008659 dated-06/07/2026, it is to inform you that the premises was inspected by officer concerned of this department on 23/07/2026 in the presence of Sh. kamal Khan (Manager) to see the functioning of fire safety equipments provided in the building. During inspection the following shortcomings were observed.

1. Width of staircase is provided 1.12m & 0.75m against requirements of 1.5m each and door width 1.09m & 0.75m against requirements of 1.5m each.
2. Fire check doors (FCD) found not provided.
3. Overhead water tank of 10,000ltr provided against requirement of 20,000ltrs.

In view of above, the application for issuance of Fire safety Certificate is cannot consider at this stage & rejected.

Yours faithfully,

7/8/26

(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier, M/s. Kalsang Restaurant Private Limited located at M-30 First Floor, M-Block Market, Greater Kailash Part-2, New Delhi-110048. (Online application No. 2026061008659 dated-06/07/2026)