GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/SZ/2026/283 Dated: 09 / 07 /2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in r/o Plot No M-50, Greater Kailash Part-II, Market, New Delhi-110048.

Sir,

Please refer to your online application no. No. 52026040702095, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 07/05/2026 in the presence of Sh. Sushant Rari the following shortcomings were observed during inspection.

1. First Aid Hose reel are provided but not functional.
2. MOEFA is provided but not functional.
3. Main Fire Pump capacity of 900 LPM is provided but not in auto mode.
4. Exit Signage's are found removed.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is cannot consider at this stage. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,

7/7/26

(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier r/o Plot No M-50, Greater Kailash Part-II, Market, New Delhi-110048. (Online application No. 52026040702095).