C-43

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2026/School/26

Dated: 08 /01 /2026

To

The Manager
M.N. Modern Public School
D-2/21, Hari Enclave, Kirari
Suleman Nagar, Delhi-110086.

Sub: - Regarding grant of fire safety certificate in r/o M.N. Modern Public School located at D-2/21, Hari Enclave, Kirari Suleman Nagar, Delhi-110086.

Sir,

Please refer to your letter received through online e-mail dated 17/12/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 29/12/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & first floors only. At the time of inspection Sh. Firoz Khan (Owner) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose is not provided.
2. Terrace level fire pump capacity of 450lpm is not provided.
3. Terrace level fire water tank capacity of 10,000 Ltr is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully

06/01/26

S.K. Dua
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi – 110085.