C/29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2026/ 161 Dated: - 09/10/2026

FIRE SAFETY CERTIFICATE

Certified that the Madhav Shree Global School, located at Plot No. 7, 8, 9, 42 & 43 out of Kh. No. 2/17 & 2/24, Rajeev Nagar Extn., Village Begumpur, Delhi-110086, comprised of ground + 02 upper floors, owned/occupied by Madhav Shree Global School, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/2011/1491 dated 07/07/2011. The said premise was re-inspected by the officer concerned of this department on 27/08/2026 in the presence of Sh. Sandeep Yadav (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules. 2010 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 09/10/2026 for a period of three years, in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the DFS Rules, 2010, printed below.

Issued on 09/10/2026 at New Delhi by

09/10/26

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Deputy Director, Delhi Municipal Corporation, Civic Centre, Minto Road, Delhi-110002.
2. The Principal, Madhav Shree Global School, located at Plot No. 7, 8, 9, 42 & 43 out of Kh. No. 2/17 & 2/24, Rajeev Nagar Extn., Village Begumpur, Delhi-110086.

Conditions for validity of fire safety certificate: -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building	Madhav Shree Global School, located at Plot No. 7, 8, 9, 42 & 43 out of Kh. No. 2/17 & 2/24, Rajeev Nagar Extn., Village Begumpur, Delhi-110086
2. Type of Occupancy	Educational Building
3. Type of Case	Renewal
4. Composition of building	Ground + 02 Upper Floors
5. Details of Previous NOC	F6/DFS/MS/2011/1491 dated 07/07/2011 (for M.D. Indraprastha Institute for Higher Educational)
6. Fire Safety directives letter No	Nil
7. Date of inspection	27/08/2026
8. Name of Inspecting Officer	ADO (Rohini)
9. Name and designation of officers From the building side	Sh. Sandeep Yadav (Manager)
10. Year of Construction	2011
11. Applicant's letter no.	Form 'I' dated 24/06/2026

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC (Part-IV) 2016 Requirements	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	02 nos.	01 Staircase and 01 ramp	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m	2.5 m x 1 and 2.20 m x 1 ramp	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	1.50 m	Provided	MR
	f. Door Size	1.20 m	Provided	MR
3.	**Compartmentation**			
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	**Smoke Management System**			
	a) Basements	NA	NA	NA
	b) Ground floor	12 a/c per hour	Natural Ventilation	MR

5.	**Fire Extinguishers**	N/24		
	a) Total numbers	06 nos.	Provided	MR
	b) Types	ABC/CO2	Provided	MR
	c) IS marking	ISI marked	Provided	MR
6.	**First-Aid Hose Reels**			
	a) Total numbers on each floor	01	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	05 mm	Provided	MR
7.	**Automatic fire detection and alarming system**			
	a) Type of detectors	NA	NA	NA
	b) Location of Main Panel	NA	NA	NA
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	NA	NA	NA
	e) Hooters' Location	NA	NA	NA
8.	**MOEFA**	NA	NA	NA
9.	**Public Address System**	NA	NA	NA
10.	**Automatic Sprinkler System**			
	a) Basement	NA	NA	NA
	b) Upper Floors	NA	NA	NA
	c) Sprinkler above false ceiling	NA	NA	NA
11.	**Internal Hydrants**			
	a) Size of riser/down-comer	NA	NA	NA
	b) Number of hydrants per floor	NA	NA	NA
	c) Hose Box	NA	NA	NA
12.	**Yard Hydrants**			
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main Pump	NA	NA	NA
	➢ Head of Main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey Pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Starting/Manual Stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	Terrace level			
	➢ Discharge of pump	450 lpm	Provided	MR
	➢ Head of the pump	40 m	Provided	MR
	➢ Power Supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14.	**Captive Water Storage for fire fighting**			
	• Underground tank capacity	NA	NA	NA
	➢ Draw-off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs.	Provided	MR
15.	**Exit Signage.**	Required	Provided	MR

N/25

16.	**Provision of Lifts.**			
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA
	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA
17.	**Standby power supply**	NA	NA	NA
18.	**Refuge Area.**			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	**Fire Control Room**			
	a) Detector System Panel	NA	NA	NA
	b) Flow Switch Panel	NA	NA	NA
	c) PA System Panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building Floor Plans	NA	NA	NA
20.	**Special Fire Protection System for Protection of special Risks, if any:**	NA	NA	NA

Note: - The earlier school's name was M.D. Indraprastha Institute for Highter Education was running at ground + 02 upper floors. Now the school's name has been changed by school management (undertaking submitted) in the name of Madhav Shree Global School is running at ground + 02 upper floor.

The fire protection systems provided in the building were checked and found in working condition at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/WZ/2022/52 dated 15/09/2022 found rectified.

Keeping in view substantial compliance of the minimum standards of fire prevention and fire safety requirements under the rules, the FSC issued vide letter no. F6/DFS/MS/2011/1491 dated 07/07/2011 renewal under rule 35 (6) of the Delhi Fire Service Rule 2010 **is recommended**.

21/09/2026

Signature of the Inspecting Officer
Name : - Paras Kumar
Designation : - ADO (Rohini)

DO/N/W

DY CFO/W2

CFO (W2)

25/09/2026

Debabrata Mukherjee

26/9/26

A.K. MALIK

CFO may issue.

8/10/26

5/10/26

A.K. MALIK