C-192

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/BP/2026/ 85

Dated: 24/03/2026

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th Floor, Minto Road,
New Delhi.

Sub:- **Rejection** of building plans from fire safety point of view in r/o M/s Madhukar Multispecialty Hospital at Plot No. 5 FC-29, Geetanjali New Delhi.

Sir,

With reference to online ID no. 10121749 dated 20.02.2026 on the subject cited above, it is informed that the referred building plans in respect of Addition/alteration in institutional building at Plot No. 5 FC-29, Geetanjali New Delhi were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcomings were observed:-

1. Fire tower is not proposed as per clause 9.3.13 of UBBL-2016/ NBC-2016, Part-IV.
2. Width of the corridors 2.4 meter at all level is not proposed as per UBBL-2016/ NBC-2016, Part-IV.

In view of the above, the building plans are **rejected** with a request to resubmit plans after rectification of above shortcomings for further consideration.

Yours faithfully,

(M. K. Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service