GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026060203344

Dated: 11-09-2026

SHORTCOMING(S)

With reference to your application ID **52026060203344** dated **11-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Maharaja Agarsain Public School** at **Ashok Vihar, Phase-IV, Delhi-110052.** from fire safety point of view in presence of **Mr. Chander, Care Taker** on dated **06/08/2026** During the course of inspection following observations were made:-

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-
1. Gaurav Dutta , A-894, Rohini, Near Bal Bharti school, Delhi, 110085
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.