GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C/94

No: F6/DFS/MS/WZ/2026/ 226 Dated: 09/06/2026

To,

The Medical Superintendent,
Manav Sevarth Trust Hospital,
Action Cancer Hospital,
A-4, Paschim Vihar, New Delhi-110063.

Sub: - Inspection report in r/o M/s Manav Sevarth Trust Hospital (Action Cancer Hospital) located at FC-34, A-4 Block, Paschim Vihar, New Delhi – 110063.

Sir,

This has reference to your E-mail ID dated 20/05/2026 and outdoor dairy no. 1413 dated 20/05/2026 regarding compliance of shortcomings issued vide letter of even no. 139 dated 23/04/2026. In this connection it is to inform you that the above said Hospital building was revisited by the officer concerned of this department on 02/06/2026 to see the compliance of the requisite fire safety measures. Sh. Mandeep Lakra (DGM Maintenance) was present at the time of inspection. Following shortcomings were observed at the time of inspection: -

1. Internal road of 6 m width found obstructed due to new construction.
2. There are only 03 no. of staircases and one ramp in Block A against the requirement of 04 staircases and one ramp.
3. Door closer of fire check doors found removed at some places.

You are advised to rectify the above-mentioned shortcoming under intimation to this department, till than the occupancy of the Building/ Premise in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours Faithfully

05/06/26

S.K. Dua
Chief Fire Officer
Delhi Fire Service