c/20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 821 Dated: 19/11/2025

To,

The Principal
M.C. Primary School
Shiv Nagar, Near Khalsa Collage,
Karol Bagh, New Delhi- 110005.

Sub: - Regarding renewal of "FSC" from fire safety point of view in r/o M.C. Primary School located at Shiv Nagar, Near Khalsa Collage, Karol Bagh, New Delhi- 110005.

Sir,

Please refer to your letter No. Nil, dated 13.10.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 03.11.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Seema Rani (Principal) was present and it was observed that school building comprised of ground plus two upper floors, and have following shortcomings: -

1. Hose reels/hydrant found provided but not functional.
2. Terrace fire pump of 450 LPM found provided but not functional.
3. Exit signage's are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

12/11/25

(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to: -

1. Director of Education, MCD, Dr. S.P. Mukherjee Civic Centre, New Delhi- 110002.