C35

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6/DFS/MS/2026/School/NZ/ 110 Dated 28/07/2026

FIRE SAFETY CERTIFICATE

Certified that the M.C.D. Primary Utkrisht Vidyalaya located at AG Block, Shalimar Bagh, Delhi-110088 is comprised of 02 Blocks- Ground plus 02 Upper floors and Activity Hall at Ground Floor Floors owned/ occupied by M.C.D. Primary Utkrisht Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with DOE circular no. 262-362 dated 17.01.2005 and verified by the officers concerned of Fire Service on 13.07.2026 in the presence of Ms. Neerja Anand (Principal) and found that the building/ premises is fit for occupancy Group B Educational with effect from 28/07/2026 for a period of 03 (Three) years subject to compliance of the conditions mentioned below:
Issued on ....28.07.2026 at New Delhi by

24/7/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director, Education, MCD, Civic Centre, Delhi.
2. The Principal, M.C.D. Primary Utkrisht Vidyalaya located at AG Block, Shalimar Bagh, Delhi-110088.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
4. This certificate cannot be treated in any case for regularizations of unauthorized construction.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **www.dfs.delhigovt.nic.in**
7. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

N-13

INSPECTION REPORT

1. Name & address of the building : M.C.D. Primary Utkrisht Vidyalaya located at AG Block, Shalimar Bagh, Delhi- 110088.
2. Type of Occupancy : Educational
3. Building Comprised of : 02 Blocks- Ground plus Two upper floors and Activity Hall at Ground Floor.
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : DOE circular No. 262-362 dated 17/01/2005
7. Date of inspection : 09/07/2026
8. Name of Inspecting Officer : R.K.Sinha, ADO (Shalimar Bagh)
9. Name and designation of officers From the building side : Smt. Neerja Anand
10. Year of Construction : 1993 as per school performa given
11. Applicant's letter No. : Outdoor Diary No. 3141 dated 01/07/2026 & E Mail ID dated 21/05/2026

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE/ Inspection report dated 28/02/2013	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	On Road	MR
	• Width of internal road	NA	NA	NA
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5 m	1.5 m & 1.36 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m for class room, 2 x 2 m for activity hall	Provided	MR
3.	**Compartmentation**			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	**Smoke Management System**			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	**Fire Extinguishers**			
	• Total numbers	12 Nos.	Provided	MR
	• Types	ABC/ CO2 Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	**First-Aid Hose Reels**			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	**Automatic fire detection and alarming system**			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

	• Hooters' Location	NA	NA	NA
8.	**MOEFA**	NA	NA	NA
9.	**Public Address System**	NA	NA	NA
10.	**Automatic Sprinkler System**			
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	**Internal Hydrants**			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	**Yard Hydrants**			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main Pump	NA	NA	NA
	➢ Head of Main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey Pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Starting/Manual Stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	• Terrace level			
	➢ Discharge of pump	450 lpm	Provided	MR
	➢ Head of the pump	40 m	Provided	MR
	➢ Power Supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14.	**Captive Water Storage for fire fighting**			
	• Underground tank capacity	NA	NA	NA
	➢ Draw-off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	**Standby power supply**	NA	NA	NA
18.	**Refuge Area.**			
	➢ Total Area	NA	NA	NA
	➢ Location	NA	NA	NA

N-15

19.	**Fire Control Room**			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	**Special Fire Protection System for Protection of special Risks, if any:**	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter of even no. 691 dated 25/08/2025.

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 262-362 dated 17/01/2005, it is **recommended to grant** Fire Safety Certificate.

ADO (S.B)
15/7/26

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/Shalimar Bagh.

DO(CND)
15/7

CFO/N2
16/7/26

Principal Director
CFO ADO
17/7/26

CFO(N2)
21/7/26

ADO/S.B
Sm. [illegible] letter is [illegible] for SSR [illegible]
ADO (S.B)
22/7/26

CFO(N2)
24/7/26

TMS