C 22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/School/2026/EZ/109 Dated: 28/07/2026

FIRE SAFETY CERTIFICATE

Certified that the **MCD Primary School** located at Biharipur, Shahdara Delhi–110090, building comprised of ground plus two upper floors only, owned/occupied by MC Primary School, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2021/NDZ/1020 dated 17/12/2021. The premise was re-inspected by the officer concerned of this department on 20/07/2026 in the presence of Sh. Santosh Kumar (Teacher) and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the said building is fit for occupancy class **"Educational" (Group B-1)** with effect from 28/07/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/07/2026 at New Delhi by

27/7/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

01/8/26

Copy to: -

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi–110053
2. The Principal, MC Primary School located at Biharipur, Shahdara Delhi–110090

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
3. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-9

INSPECTION REPORT				
1	Name & Address of the Building	**MCD Primary School**, Biharipur, Shahdara North, Delhi–110090		
2	Type of Occupancy	Educational (Group B-1)		
3	Building Comprised of	G+02 upper floor only.		
4	Type of Case	Renewal		
5	Details of Previous FSC	F6/DFS/MS/School/2021/NDZ/1020 dt. 17/12/2021		
6	Fire Safety Directives Letter No	NBC Part-IV		
7	Date of Inspection	20/07/2026		
8	Name of the Inspecting Officers	ADO (Gokalpur)		
9	Name & Designation of Officers from the building side	Sh. Santosh Kumar (Teacher)		
10	Year of construction	2012		
11	Applicant letter / Online Application	No. **520260701298**		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6.0 mtr	6.0 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	➢ Upper floors	02 Nos	02 Nos	MR
	➢ Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	➢ Upper floors	1.5 mtr	1.50 m x 2	MR
	➢ Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	➢ Fire check door	N/A	N/A	N/A
	➢ Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01 Nos	Provided	MR
	e. Width of corridor	1.5 mtr	Provided	MR
	f. Door size	1.0 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	09 Nos	09 Nos	MR
	• Types	ABC/CO_2	Provided	MR
	• ISI Marking	Required	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01 No	Provided	MR
	• Length of hose-reel hose.	30 mtr	Provided	MR
	• Nozzle Diameter	05mm	Provided	MR

7	Automatic Fire Detection and Alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors.	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➢ Discharge of main pump.	N/A	N/A	N/A
	➢ Head of main pump.	N/A	N/A	N/A
	➢ Number of main pumps.	N/A	N/A	N/A
	➢ Jockey Pump output.	N/A	N/A	N/A
	➢ Jockey Pump head.	N/A	N/A	N/A
	➢ Standby Pump output.	N/A	N/A	N/A
	➢ Standby Pump head.	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➢ Discharge of pump.	450 LPM	Provided	MR
	➢ Head of pump.	40 mtr	Provided	MR
	➢ Power supply.	Required	Provided	MR
	➢ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➢ Draw-off connection.	N/A	N/A	N/A
	➢ Fire Service Inlet.	N/A	N/A	N/A
	➢ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	10,000 ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

N-11

19.	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any.			N/A

The fire protection systems provided in the building were checked, tested at random and **found functional at the time of inspection**. Further, the shortcomings communicated by this department vide Application ID 52026022701298 dated 13.03.2026 have been complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/School/2021/NDZ/1020 dt. 17/12/2021, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, **DFA is put up for approval** & signature please.

S Kumar 21.07.26

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (Gokal Pur)

DO (ED)

21/07/26

CFO (East Zone)

22/7/26

Principal Director

CFO to [illegible]

24/7/26

CFO (ED)

24/7/26

ADO/GP

Sir, F.T letter is putup for your kind.pl

S Kumar 27.07.26

CFO(east)

27/7/26

MS