c114

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2025/ 820 Dated: - 19/11/2025

To,

The Principal,
MCD Primary School (Girls),
Prem Nagar- I, New Delhi-110008.

Sub: - Regarding issuance of "Fire Safety Certificate" in r/o M.C.D. Primary School (Girls) at Prem Nagar-I, New Delhi- 110008.

Sir,

Please refer to your letter No. Nil, dated 14.10.2025, received in this office through outdoor dairy No. 7129 dated 15.10.2025, on the subject cited above. In this connection it is to inform you that the above said school building have been inspected by the officer concerned of this department, in presence of Sh. Sanjay Kapoor (In-charge) on dated 03.11.2025, to check the status of the shortcomings already pointed out by this department vide letter No. F.6/DFS/MS/2014/School/494 dated 28.02.2014 (copy enclosed) which are still not complied.

In view of the above, issuance of 'Fire Safety Certificate' cannot be considered at this stage. You are requested to follow the direction in to given in the letter dated 28.02.2014 (copy enclosed) under intimation to this department for taking further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

17/11/25

(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to:-

1. Director of Education, MCD, Dr. S.P. Mukherjee Civic Centre, New Delhi- 110002.

C/10

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

E-mail : gargatul@hotmail.com Ph. 011-26189168

**No: F.6/DFS/MS/2014/** Sch nd/494 **Dated:** 28/02/14

To

The Principal,
M.C. Primary Boys School,
Prem Nagar-II, New Delhi-110008.

Sub: - Regarding grant of Fire Safety Certificate in r/o M.C. Primary Boys School, Prem Nagar-II, New Delhi-110008.

Sir,

Please refer to your letter No. Nil, dated 18.12.2013 received on 07.02.2014 on the subject cited above. In this connection, it is to inform you that the inspection of above said premises have been carried out by officer concerned of this department on 22.02.2014 to see the compliance of the requisite Fire Safety measures. Sh. Lalit Kumar (Teacher) was also present at the time of inspection.

During the course of inspection it was observed that the school building is comprised of ground floor plus three upper floors. The upper floors are served by two staircases having width 152 cms & 114 cms respectively. The building is approachable to the fire fighting vehicles, but the building does not meet the required norms in the light of Delhi Fire Service Act 2007, and Rule 2010, provisions contained in NBC of India (part-IV) due to the following shortcomings: -

1. First Aid Hose Reels are not provided in the school building.
2. Fire Pump of 450 LPM discharge with 30 M head is not provided.
3. Overhead water storage tank of 10000 ltr cap. is not provided.
4. Exit signs are not provided in the school building.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for grant of Fire Safety Certificate.

Yours Faithfully

26/2/14

(Atul Garg)
Dy. Chief Fire Officer
o/c Delhi Fire Service

Copy to:- 1. The Principal,
M.C. Primary School,
Prem Nagar-I, New Delhi-110008.

14.7.14
Principal
North M.C. Primary Girls School
Prem Nagar-I
New 110008