GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 744 Dated: 23/09/2025

To

The Principal,
MCD Primary School,
Rangpuri Pahari, New Delhi 110037.

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o M/s MCD Primary School, Rangpuri Pahari, New Delhi 110037.

Sir,

This has reference with letter np 118/23/08/2025/RPP dated 22/08/2025 received through DFS outdoor diary no 5538 dated 02/09/2025 on the subject cited above. In this connection, it is to inform you that the above-mentioned premise was visited by the officer concerned of this department on 15/09/2025 in the presence of Mr. Soun (Principal) and observed that the shortcoming intimated vide letter of even no 1989 dated 02/08/2017 & letter of even no 613 dated 27/09/2022 has not been complied yet. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate **is rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

23/9/2025

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:
1. The Director of Education, MCD, Civic Centre, Minto Road, New Delhi-110002

C/23

GOVERNMENT OF NATIONAL CAPITAL TERRITOTY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001
Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/School/2017/SZ/ 1989 Dated: 24/8/17....

To

The Principal,
S.D.M.C. Primary School,
Rangpuri Pahari, New Delhi-110037

Sub.:- **Renewal of NOC in respect of S.D.M.C. Primary School, Rangpuri Pahari, New Delhi-110037.**

Sir,

This has reference to your letter No. Nil dated 20/03/2017 received in this office vide outdoor dairy No. 3455 dated 23.03.2017 on the subject cited above. In this connection, it is to inform you that the concerned nominated authority of this department visited the school premises on 02/05/2017 in your presence and observed that the department issued FSC vide letter no. F.6/DFS/MS/School/2010/3041 dated 22-08-2012 for school building comprised of ground plus one upper floor and now the school management constructed a new block comprised of ground plus two upper floors. the shortcoming observed are as below: -

1. 10 No's of Fire extinguishers found provided, which are inadequate, 05 No's more fire extinguishers (ABC /Co2), ISI marked to be provided.
2. First aid hose-reel not found provided.
3. Terrace level pump capacity 450 LPM with head 40 mtr not found provided.
4. Captive water storage for firefighting cap. 10,000 ltrs not found provided.
5. Exit signage not found provided.

In view of the above shortcomings, renewal of FSC cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,

Vipin Kental
Chief Fire Officer

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/School/2022/SZ/ 613 Dated: 27/9 /2022

To

The Principal,
SDMC Primary School,
Rangpuri Pahari, New Delhi 110037.

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o SDMC Primary School, Rangpuri Pahari, New Delhi 110037

Sir,

This has reference with letter received through outdoor diary no 5203 dated 05/09/2022 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15/09/2022 in the presence of Smt. Nisha Rani (Principal) and observed that the shortcoming intimated vide letter of even no 1989 dated 02/08/2017 has not been complied yet. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:

1. The Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002